APPLICATION No.: 5262	TAP CLEARED			
LOCATION: 83 Rockland St	DATE	BEF.	AFT.	REMARKS
OWNER:				
MEASURES: Sept. 29, 1886 E X Crapo St S X N Line Rockland St E X W Line House O.6 ft 1" Copper Service 11/20/2018 Lead Service Replacement Program Phase 1, Contractor P Gioioso & Son Type CU, Diameter 1in, Water pressure 95 Distance from main to curb stop (Ft) 21.5 Distance from curb stop to meter (ft) 12 Distance from curb face to curb stop (ft) 1.4 Depth of service (Ft) 4.1 Total length ofnew pipe installed (ft) 21.5 Curb stop replaced: Yes size 1" Corporation replaced: Yes size 1" Ball valve replaced: No size 3/4" Remarks: 1-3/4 union installed 1 LF outside curb stop				

