

APPLICATION No.: 5302

TAP CLEARED

LOCATION: 307 Purchase St

OWNER:

7/27/2013 Ream

31-313

July 30, 1886

MEASURES:

N X Grinnell St

126.0 ft

E X W Line Purchase St

7.2 ft

S X N Line House

8.7 ft

1" Copper Service

08/06/2018 Lead Service Replacement Program

Phase 1, Contractor P Gioioso & Son

Type CU, Diameter 1in, Water pressure 90

Distance from main to curb stop (ft) 7

Distance from curb stop to meter (ft) 20.1

Distance from curb face to curb stop (ft) 1.8

Depth of service (ft) 4.3

Total length of service installed (ft) 20.1

Curb stop replaced: No size 3/4'

Corporation replaced: No size 3/4"

Ball vavle replaced: Yes size 1"

Remarks: 1-3/4 Union installed 1.0 LF Outside curb stop

METER HISTORY

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST		REMARKS

CHARGE OUTS