

APPLICATION No.: 5389

TAP CLEARED

LOCATION: 87 Acushnet Ave

DATE

BEF.

AFT.

REMARKS

OWNER:

'31-313

MEASURES:

Oct 15th, 1886

N from Potomska St 71.9'

E from W line Acushnet Ave 7.3'

N from S line house 3.3'

1" COPPER SERVICE

5-9-19: Lead service line replacement program  
phase1: Type CU, Diameter 1; Water Pressure 100

Contractor: P. Gioso &amp; Sons

Distance from main to curb stop 8'

Distance curb stop to meter 20'

Distance from curb face to curb stop 1.5'

Depth of service 4'

Total length of new pipe installed 28'

Curb stop replaced: YES Size 1"

Corporation replaced YES: Size 1"

Ball Valve furnished YES: Size 1"

[illegible]

### CHARGE OUTS

