

APPLICATION No.: 5423

TAP CLEARED

LOCATION: 66-70 Dartmouth St.OWNER: Charles M. Grace Andrews CosmosMEASURES: 5/8" H lead Nov. 26, 1886E from Dartmouth St. 40.4 ft.N from S line Grinnell St. 6.7 ft.W from E line house 7.5 ft.

June 21, 1963 Renewed from main to 4 ft. from main

4 ft. 3/4" copper tubing

1 5/8" reused corp. cplg.

1 lb. wiping solder

Tap reamed

1 street cut: 5' x 2' Warrenite

250 Compressor: 1/2 hr.

Lownds

Jakusikk

9/10/2018: Lead service line replacement progra
phase 1, Contractor: P. Giosio & Sons

TYPE: CU, Diameter 1, Water Pressure 80

Distance from main to curb stop N/A

Distance curb stop to meter 12.8'

Distance from curb face to curb stop 1.6'


Depth of service 3.8'

Total length of new pipe installed 12.8'

Curb stop replaced NO Size N/A

Corporation replaced: NO Size N/A

Ball valve furnished YES size 1"

[illegible]

APPLICATION No.: 5423

TAP CLEARED

LOCATION: Grinnell Cor. 32-36 Dartmouth

OWNER:

MEASURES:

5/8"

| | | |
|---------------|-----------|------|
| E from | Dartmouth | 40.4 |
| N from S line | Grinnell | 6.7 |
| W from E line | House | 7.5 |

October 1977 D .W. White Const. installed new 8" main on Grinnell St.
and renewed service from main to curb stop with 3/4" copper tubing
No records on service were ever reported.
This information from Don Taber Dec. 28, 1992

DATE

BEF.

AFT.

REMARKS

[illegible]

CHARGE OUTS