

APPLICATION No.: 5467

TAP CLEARED ✓

LOCATION: 202 Grinnell St.

OWNER: William T. Rogers

MEASURES: 5/8" H lead Apr. 11, 1887

W from Orchard St. 10.4 ft.

N from S line Grinnell St. 7.6 ft.

W from E line house 6.2 ft.

Approx. Oct. 1977 This service was renewed from the main to the curb stop by Contractor, no records on service card.

3/25/93: Renewed from curb stop to ins. cellar (10ft ins. prop line) Stock: 16ft 3/4" copper tubing same curb stop same Caldwell stop box =====

OCT. 1977 D.W. WHITE CONST. INSTALLED NEW 8" MAIN ON GRINNELL ST. 3/4" SERVICE FROM MAIN TO CURB STOP WITH 3/4" COP TUB, NO RECORD ON SER. CARD WERE EVER REPORTED

THIS INFO FROM DON TABER ENG. DEC 28, 1992

8/14/06 Gas Co. broke sewer service while installing new gas main. Replaced from outside of foundation (curb line). Stock: 4 ft. 6" PVC; 2 rub cplgs (Fernco)

DATE

BEF.

AFT.

REMARKS

3-25-93

9313 2565

[illegible]

CHARGE OUTS.

[illegible]

#102 APPLICATION No.: 5467

LOCATION: Orchard S.W. Cor. Grinnell

TAP CLEARED

OWNER: _____

MEASURES: 5/8"	H lead	4-11-1887
W from	Orchard	10.4 ft.
N from S line	Grinnell	7.6 ft.
W from E line	House	6.2 ft.

October 1977 D .W. White Const. installed new 8" main on Grinnell St.
and renewed service from main to curb stop. with 3/4" copper tubing

No records on service were ever reported.

This information from Don Taber Dec. 28, 1992

METER HISTORY

[illegible]

CHARGE OUTS

This image shows a blank, aged, cream-colored page, likely an endpaper or flyleaf of a book. The paper has a slightly textured appearance with some faint smudges and discoloration, particularly towards the top and right edges. The left edge of the page shows the binding, with visible stitching or staples. There is no text or other markings on the page.