

LOCATION: 184 Arnold

OWNER: John J. Frances

MEASURES: 5/8" L lead May 27, 1887
 E from Chancery 15.2 ft.
 N from S line Arnold 6.4 ft.
 W from E line House 8.9 ft.
 Change to 3/4" 5-5-65

June 2, 1959 Renewed from 1/2 ft. outside curb stop
 to 1/2 ft. inside curb stop.

1 ft. - 3/4" copper; 1 - 3/4" cop to cop stop, fig. 4155
 2# wiping solder.

May 5, 1965 Renewed service from 6" inside curb stop
 to meter inside cellar.
 13 ft. - 3/4" copper; 1-3/4" copper cplg. , A-1525;

11/29/93: Renewed from main to curb stop (installed new curb stop)
 Stock: 9ft 3/4" copper tubing 1-3/4" curb stop
 1-Caldwell stop box 1-3/4x5/8 Fig 413
 NOTE: REMOVED COPPER CPLG. A-1525 SOLDERED FROM INSIDED OLD CURB
 STOP & INSTALLED NEW CURB STOP

+++++

DATE

BEF.

AFT.

REMARKS

11/29/93: tap reamed

11-28-93 934900063

METER HISTORY

CHARGE OUTS

[illegible]