

| APPLICATION No.: 5585 | | TAP CLEARED ✓ | | | |
|---|-----------------------------|---------------|------|--------|-----------|
| LOCATION: | 22 Ocean Stable | DATE | BEF. | AFT. | REMARKS |
| OWNER: | H. Ambadgis | | | | 9142-1464 |
| MEASURES: | 5/8 | 10/16/91: | TAP | REAMED | |
| | S from Arnold 109.0 ft. | | | | |
| | W from E line Ocean 7. ft. | | | | |
| | N from S line Barn 11.2 ft. | | | | |
| 10/16/91: R enewed from main to 1.6 ft. ins. curb stop | | | | | |
| Stock: 17.6ft. 3/4" copper tubing 1-3/4" curb stop | | | | | |
| 1- Caldwell stop box 1-3/4x5/8 lead-cop adapt. xs | | | | | |
| 1- 3/4x5/8 Fig.413 | | | | | |
| ===== | | | | | |
| NOTE: Tele. duct 2 ft. E x curb stop in sidewalk | | | | | |
| Cable TV - 1 ft from main. | | | | | |
| Reason did not go to property line is because of tele. duct - no room to dig near line. | | | | | |
| Tel. duct not marked. | | | | | |
| 2 Elec. wires in front of curb stop on sidewalk. | | | | | |
| 8/26/92: Pavao const. renewed from main to a point 1.6ft ins. | | | | | |
| curb stop Pavao const. supplied stock & labor | | | | | |
| CHAP 90 Stock: 21.0ft 3/4" copper tubing | | | | | |
| 1-3/4" curb stop 1-Caldwell stop box 1-3/4x5/8 lead-cop adapt.xs | | | | | |
| 1-3/4" corp tap on new main NOTE: WHILE INSTALLING NEW 6" | | | | | |
| DUCTILE MAIN PAVAO CONST. PULLED COPPER SER.FROM 1 1/2 FT INS.CURB | | | | | |
| STOP HAD TO BE REPLACED 1991 CUT NOT DONE YET. Ins.J.Rodrigues | | | | | |
| ===== | | | | | |

[illegible]