

APPLICATION No.: 5620

TAP CLEARED

LOCATION: 204 Blackmer St.

OWNER: Sebastiao E. Pinheiro

MEASURES: 1/2" H lead Aug. 3, 1887

E from County St. 74.9 ft.

N from S line Blackmer St. 6.9 ft.

W from E line house 8.0 ft.

9/16/93; Renewed from main to prop line Stock: 14ft 3/4" copper
 tubing 1-3/4" curb stop 1-Caldwell stop box 1-3/4x5/8 lead-
 cop adapt.xs 1-3/4x5/8 Fig 413
 =====

12.19.2018 - Lead Service Line Replacement Program

Contractor: P. Gioioso and Sons

Type: CU, Diameter (in) 1, Water Pressure (PSI) 95

Distance from main to curb stop (ft): N/A, Distance
 curb stop to meter (ft) 15.5, Distance from curb face to curb
 stop (ft) 2, Depth of service (ft) 4, Total length of new
 pipe installed (ft) 15.5

Curb stop replaced: No, Corporation replaced: no,
 Ball Valve Furnished: Yes, Size 1"

DATE

BEF.

AFT.

REMARKS

9-16-93

933804972

9/16/93: tap reamed

METER HISTORY

CHARGE OUTS

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS

