

OWNER:
31-313

APPLICATION No.: 5624

TAP CLEARED

DATE _____

BEF.

AFT.

REMARKS

MEASURES:

3/4 copper C/S to meter
6.10.2021 used existing meter

E x E	line	Cottage St	64.4
-------	------	------------	------

S x N line Willis St 7.3

E x W line house 23'

w x E line house 3'

s x s line house 14'

main to prop. line 24'

pipe inside prop.	10'
-------------------	-----

Contr. Smith Insp. Percy R

METER HISTORY

[illegible]

CHARGE OUTS

APPLICATION No.: 5624

TAP CLEARED ✓

LOCATION: 97 Willis

OWNER: A. T. Quinn

MEASURES: 3/4"

E from Cottage 65.6ft.
S from N Willis 7.3 ft.
W from E house 2.2 ft.

Dec. 24, 1973 Repaired leak at the corporation tap.
1 wipe joint.

Nov. 18, 1971 Renewed from 1/2 ft. outside curb stop to property line.
8 ft. of 3/4" copper tubing 1 3/4" Hays curb stop
2 wipe joints

2/5/2020: DPI, Rui Martins- replaced lead leaking service
from main to curb stop,
1- 3/4" curb stop valve
1- cast iron curb stop box
1- 5/8" corp adapter
24ft of 3/4" copper tubing

DATE

BEF.

AFT.

REMARKS

12/24/73

Reamed

[illegible]

CHARGE OUTS