

APPLICATION No.: 5683

TAP CLEARED ✓

LOCATION: 135 WillisOWNER: Jennie Zerbonne

MEASURES:

01/01/1887

3/4"

E from	Shawmut Av.	74.2 ft.
S from N	Willis	6.0 ft.
W from E	house	9.6 ft.

Oct 2, 1997:

Renewed from 1ft outside curb stop to a point 5ft ins. sidewalk  
Stock: 6ft 3/4" copper tubing 1-3/4" curb stop  
1-caldwell stop box 2= lead-cop adapt. xxs

=====

9/27/05 South Shore Utility renewed service from main to property line.

-----

8/6/09 - Nelson Cardoso renewed service from curb stop to meter  
with 3/4" copper tubing; Owner charged \$70 inspection fee, service  
was previously off. Inspected by Percy Reynolds

Additional measures:

E from W line House	14.0
S from S line House	10.0
Main to Property Line	6.0
Pipe inside property	26.0

-----

DATE

BEF.

AFT.

REMARKS

10/2/97

tap reamed 10/2/97

97 4005904

[illegible]