

APPLICATION No.: 5685

TAP CLEARED ✓

LOCATION: 33 Harrison St.

OWNER: Frank S. & Mary Marks, J.T.

MEASURES: 5/8" H lead Oct. 28, 1887

N from Oak St. 113.8 ft.

E from W line Harrison St. 6.5 ft.

S from N line house 0.4 ft.

C.S. LEAK

8-16-04

8/17/04 Renewed from main to property line. Stock: 14 ft. 3/4" copper tubing; 3/4" curb stop; Caldwell stop box; 5/8" x 3/4" lead-cop adapt. XXS; 5/8" x 3/4" Fig. 413 Tap reamed

NOTE: Repaired 4 ft. section of sewer. Stock: 4' section 6" PVC; 2 - clay-plastic cplgs.

[illegible]

CHARGE OUTS

[illegible]