APPLICATION No.: 5830		TAP CLEARED			
LOCATION: 22 North	DATE	BEF.	AFT.	REMARKS	
OWNER: Harry P. Sowe			8-27-99	1999350 3744	
MEASURES: 5/8" Copper 01-01-1988					
W from Park 117.6 ft. 123.6	2/14/11	10:00		2011-0201874	
N from Sline North					
E from W line House 3.8 ft. 1.7 N x N line front step 3.7					
May 28, 1962 Renewed from 1 ft. outside burb stop to					
3 ft. inside curb stop. 3 ft. of copper tubing type K, soft		a .			
1 3/4" cop. to cop. stopy fig. 415 2 lbs. wiping solder			14		
		1			
March 15, 1949 New form curb stop to inside cellar.		73			
17 ft. of 5/8" H. Lead pipe					
Jan. 14, 1976 Renewed from the new 30" main in North					
St. to the property line.					
14 ft 3/4" Copper tubing 3/4" Jones corporation					
3/4" Jones curb stop Buffalo stop box 5/8" x 3/4" Ford lead to copper adaptoe XS (at prop line)					
2/15/11 - City crew renewed water service from 1/2 ft outside curb stop to inside cellar (7 ft inside prop line					
12 ft -3/4" copper tubing; 1 -3/4" curb stop; 1 Caldwell)				
stop box. Foreman: D. Perry					
			The state of the s		

METE	RH	ISTO	DRY						
DATE	SET	SIZE	MAKE	NUMBER	READING		TEST	-	REMARKS
12-15-6	1	5/8	Hersey F	637349	The state of the s				
				Mrs. Metevier	990-8743				
8/23	/99	Per	JG - get punc	h for renewal.	has leak in	is bu	ildi	ng	(9 ft. punch
		100		k inside from o		pro	p li	ne.	
		1		stop leak (outs	The second secon				
10/29/				rb stop & tap (k c/s to proper				ne	home
	-			me water in cel					
9/21	/00	16	ak is inside o	ellar per M. Ro	se		1		
9/18	/00	016	jarz inside o	urb stop leak					
					La de				
					2				