

APPLICATION No.: 5882

TAP CLEARED

L150C1

LOCATION: 137 Bonney St.

OWNER: Mary Da Ponte

MEASURES: 5/8"

H ~~lead~~ COPPER July 17, 1888

N from

Rockland St. 84.2 ft.

E from W line

Bonney St. 6.4 ft.

S from N line

house 4.6 ft.

May 19, 1970 Reamed tap - Renewed from the main to a point 2½ ft. from the main.

2½ ft. - 3/4" copper tubing; 1 wipe joint; 1-3/4" x 3/4" Hays corp. cplg.

Dec. 10, 1980: Renewed from 6" outside curb stop to the line.

5.5 ft.-3/4" copper

1-3/4" curb stop 1-Caldwell stop box

2-5/8" x 3/4" lead-cop. adapt. XXS

10/4/89: Renewed from prop line to inside cellar

Stock: 7 ft. 3/4" copper tubing 1-3/4x3/4 cop to cop cplg. comp at prop line. -- used same curb stop box

10.09.2018 - Lead Service Replacement Program

Contractor p.gioioso and sons

Type CU, Diameter (in) 1, Water pressure (PSI) 100

Distance from main to curb stop(ft) 9, Distance curb stop to meter (ft) n/a, Distance from curb face to curb stop

(ft) 2.0, Depth of service (ft) 3.7, Total length of new

pip

BRADBURY-WARING, INC.

DATE

BEF.

AFT.

REMARKS


8940-2614

✓

METER HISTORY

CHARGE OUTS

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS



APPLICATION No.: 5882

TAP CLEARED

LOCATION: 137 Bonney St

OWNER:

31-313

MEASURES:

pipe installed (ft) 19

Curb stop replaced: Yes, Size 1"

Corporation replaced: Yes, Size 1"

Ball Valve Furnished: No, Size N/A

DATE

BEF.

AFT.

REMARKS

[illegible]