

APPLICATION No.: 5890

## TAP CLEARED

LOCATION: 37 Crapo St

OWNER: \_\_\_\_\_

31-313

MEASURES: July 24, 1888

N X Rockland St 79.9 ft

E X W line Crapo St 6.0 ft

N X S line House 10.0 ft

1" Copper Service

10/02/2018 Lead service line replacement program

Phase 1, Contractor P. Gioioso &amp; SOn

Type CU, Diameter (In) 1, Water pressure 90

Distance from main to curb stop (ft) 7.0

Distance from curb stop to meter (ft) 13.8

Distance from curb face to curb stop (ft) 2.5

Depth of service (ft) 3.5

Total length of new pipe installed(ft) 13.8

Curb stop replaced: no size 3/4"

Corporation replaced: no size 3/4"

Ball valve replaced: yes size 1"

Remarks: 1-3/4" union installed 1 LF outside  
curb stop

DATE

BEF.

AFT.

REMARKS

09/01/99

[illegible]