

APPLICATION No.: 5906

TAP CLEARED

LOCATION: 1808 ACUSHNET AVE

OWNER: ARCADE MARCOUX

MEASURES: 5/8" H LEAD JULY 30, 1888  
N from NO. FRONT 375.5 ft  
W from E LINE ACUSHNET AVE 9.5 ft  
N from N LINE HOUSE 2.4 ft  
APPROX. N X BATES ST 110 ft

Aug 29, 1996:

Renewed from a point 13ft west of curb stop to a point 16ft  
Stock: 3ft 3/4" copper tubing 1-3/4" curb stop 16ft outside c.s.  
1- 3/4 x 3/4 cop-cop cplg.comp 13ft outside c.s.

=====

DATE

BEF.

AFT.

REMARKS

[illegible]

CHARGE OUTS



APPLICATION No.: 5906---5/8"

TAP CLEARED

LOCATION: 1808 Acushnet Avenue

OWNER: Arcade Marcoux

MEASURES: 5/8" H.lead July 30, 1888  
 N from N.fromt 375.5 ft.  
 W from E line Acush. Ave. 9.5 ft.  
 N from N line house 2.4 ft.

APPROX. NX BATES ST. 110 FT.

March 3, 1958 Renewed from a point 13 ft. outside  
 curb stop to a point 2 ft. inside curb stop;  
 15 ft. - 3/4" copper tubing; 1-3/4" copper stop, fig. 415  
 2 lbs. wiping solder; 2-3/4" cop. to cop. cplg. A-1551  
 1-3/4" copper stop (used)

12/29/78: Renewed from main to 2 ft. front of main.  
 2 ft. - 3/4" copper; 5/8" x 3/4" lead-cop. adapt. XXS; 5/8"  
 x 3/4" Fig. 413;

7/16/93: Renewed from curb stop to a point 3ft ins. curb stop  
 Stock: 3ft 3/4" copper tubing same curb stop  
 same Caldwell stop box 1-3/4x5/8 lead-cop adapt. xxs

=====

Nov. 1, 1995: Norman Enterprises renewed from 3.5ft ins. curb stop  
 to ins. cellar (24ft ins. prop line)  
 Cont. supplied all stock & will maintain trench  
 27ft 3/4" copper tubing 1-3/4x3/4 cop-cop cplg. comp 3.5ft  
 ins. curb stop Insp. M Rose III

NOTE: SERVICE RELOCATED NOW GOES ALONG FOUNDATION  
 NORTH SIDE BLDG.

DATE BEF. AFT. REMARKS

7-16-93 9329 6203

12/29/78 Tap reamed

954306562

8/28/96

963503459.



## CHARGE OUTS

[illegible]