

APPLICATION No.: 5917

LOCATION: 68 Acushnet Ave

TAP CLEARED

OWNER:

31-313

MEASURES: Aug 9th, 1888

S from Potomska 160.0'

W from E line Acushnet Ave 6.8'

S from N Line house 9.4'

1" COPPER

10-26-2018: Lead service line replacement
program phase 1: TYPE CU, Diameter 1; Water Pressure 100

Contractor: P. Gioioso & sons

Distance from main to curb stop 20'

Distance curb stop to meter 21'

Distance from curb face to curb stop 1.5'

Depth of service 3.8'

Total length of new pipe installed 21'

Curb stop replaced:NO Size 3/4"

Corporation replaced:NO Size 3/4"

Ball Valve furnished: YES Size 1"

Remarks: 1- 3/4" installed 1LF outside curb stop

DATE

BEF.

AFT.

REMARKS

9-3-97: Tap reamed

METER HISTORY

CHARGE OUTS

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS

