

APPLICATION No.: 6007

TAP CLEARED

LOCATION: 17 Jenney

OWNER: Annien May Woolam

MEASURES: 5/8"

N from	Court	159.0 ft.
E from W line	Jenney	5.2 ft.
N from S line	House	7.4 ft.

✓ March 24, 1975 Renewed from 1½ ft. outside curb stop
to a point 3½ ft. inside curb stop.

5 ft. - 3/4" Copper tubing 1 wipe joint
3/4" Curb stop Caldwell Stop Box
5/8" lead to copper adaptor XS

- - -

✓ 7/26/94: Renewed from main to 2ft outside prop line

Stock: 10ft 3/4" copper tubing 1-3/4" curb stop

1-Caldwell stop box 1-3/4x5/8 lead-cop adapt.xs 1-3/4x5/8 Fig 413

NOTE: FIXED SEWER INSTALLED 2FT PIECE OF 6" PVC THRU STREET

=====

10/6/2008 West End Water Main Rehab Proj. - Perrina Construction tied this
service into new water main.

1-1" Corp. Tap; 1-1" Curb Stop, 1-1"x3/4" Reducer

Inspected by: Tim Ives, CDM

DATE

BEF.

AFT.

REMARKS

7-26-94

94300185-0

7/26/94: tap reamed

[illegible]

CHARGE OUTS

[illegible]