

APPLICATION No.: 6050

TAP CLEARED

LOCATION: 183 Parker

DATE

BEF.

AFT.

REMARKS ✓

OWNER:

MEASURES: 3"

C.I.

8-20-1888

W from

Caroline

234.0 ft.

N from S line

Parker

29.0 ft.

August 1, 1977 Repaired leak at Sgt. Carney plot.
10 ft. - 1" copper tubing 1" cop to cop compression cplg.
1" x 1" cop to lead adaptor

8/2/11 - City crew repacked gate valve that was leaking

Foreman: Frank Bento -----

Service Killed c main
6/30/2017 mw

8/2/11 8:30 2011-3203017

METER HISTORY

[illegible]

CHARGE OUTS