

APPLICATION No.: 6062

TAP CLEARED 8442-2237 ✓

LOCATION: 564 So. Second St.

OWNER: Joseph F. Augusto

DATE

BEF.

AFT.

REMARKS

7-28-55

Reamed

## MEASURES:

 $\frac{1}{2}$ "

H lead

Dec. 27, 1888

S from

Division St.

55.3 ft.

W from E line

So. Second St.

6.5 ft.

S from N line

house

9.4 ft.

-----  
July 28, 1955 Renewed from main to a point 1 ft. from main  
1  $\frac{1}{2}$  ft. of  $\frac{3}{4}$ " copper tubing 1  $\frac{3}{4}$ " cop. to I.f. cplg.  
1 wiped joint  
-----

Oct. 18, 1984: Renewed from 1/2' outside curb stop to a  
point 3.8 ft. Stock: 4.3 ft.  $\frac{3}{4}$ " copper tubing  
1  $\frac{3}{4}$ " curb stop 1 Caldwell stop box 2  $\frac{5}{8}$  x  $\frac{3}{4}$   
lead to cop adapt. XS  
-----

[illegible]

## CHARGE OUTS

[illegible]

APPLICATION No.: 6062

TAP CLEARED

LOCATION: 564 So. Second St

OWNER:

31-313

MEASURES:

Dec 27, 1888

S from Division St 55.3'

W from E line So. Second St 6.5'

S from N line house 9.4'

1" COPPER SERVICE

5-2-2019: Lead service line replacement program

Phase 1, Contractor P. Gioioso &amp; Son

TYPE CU, Diameter 1', Water Pressure 100

Distance from main to curb stop 20'

Distance curb stop to meter 18.5'

Distance from curb face to curb stop 1.5'

Depth of service 4'

Total length of new pipe installed 38.5'

Curb stop replaced: YES Size 1"

Corporation replaced: YES Size 1"

Ball Valve furnished: YES Size 1"

DATE

BEF.

AFT.

REMARKS



[illegible]