

✓ APPLICATION No.: 6064

TAP CLEARED

LOCATION: 57 Winsor St

DATE _____

BEF.

AFT.

REMARKS

OWNER:

9/4/92 Ream

31-313

MEASURES: E X	397.7 ft
S X N Winsor St	8.7 ft
E X W House	12.7 ft

1" Copper Service 7/19/2019

Lead Service Line Replacement Program

Phase 1, Contractor P Gioioso & Son

Type CU, Diameter 1in, Water pressure 100

Distance from main to curb stop (ft) 20

Distance from curb stop to meter (ft) 15

Distance from curb face to curb stop (ft) 2.0

Depth of service (ft) 3.4

Total length of new pipe installed (ft) 9.5

Curb stop replaced: No size 3/4"

Corporation replaced: No size 3/4"

Ball valve replaced: No size 3/4"

Remarks:

Unable to pull service, connected to exisiting copper service line at foundation		
--	--	--

1-3/4" union installed 2 ft outside curb stop

[illegible]