APPLICATION No.: 609		TAP CLEARED			
LOCATION: 1558 Purchase	DATE	BEF.	AFT.	REMARKS	
OWNER: N.B. Fire Dept					
MEASURES: 5/8" COPPER					
N from N line Franklin 40.0					
W from E line Purchase 7.8 S from N line Engine house 1 3.5					
AJuly 12, 1973 Renewed from 6" outside curb stop to inside cellar.					
13 ft 34 " copper 3/4" Hays curb stop 5/8" x 3/4" Ford lead to copper adaptor XXS					
5/0" x 3/4" Ford lead to copper adaptor XXS					
July 16, 1982 Renewed from the main to 1 ft. inside					
curb stop.  29 ft. = 3/4" Copper tubing 3/4" Curb stop					
29 ft 3/4" Copper tubing 3/4" Curb stop Caldwell Stop Box 3/4" x 5/8" Fig. 413 Tap reamed 3/4" x 5/8" lead to copper adaptor XXS					
Tap reamed 3/4" x 5/8" lead to copper adaptor XXS NOTE: This service was supposed to have been new from					
curb stop to cellar. Found lead at curb stop and still					
going 1 ft. inside curb stop.  Cruz Const. Sewer Proj.					
Sept. 1983 Renewed from curb stop to property line. 6.5 ft 3/4" copper tubing 1 - 3/4" curb stop PURCHASE ST. WIDENING					
PURCHASE ST. WIDENING					
16'n					

METER HISTORY								CHARGE OUTS				
DATE	SET	SIZE	MAKE	NUMBER	READING	TEST		TEST		TEST REA		
	OUT											
12-30-37		1"	HeresyF	1710932								
						- 17						
						48						
						25.748						
	14.3											
								-				
	-											