

APPLICATION No.: 6094

TAP CLEARED

LOCATION: 125 Rivet & 90 Purchase

OWNER: Sun Valley Realty, Inc. of F. R.

MEASURES:

$\frac{1}{2}$ " H lead Mar. 23, 1889

E from Purchase St. 24.8 ft.

S from N line Rivet St. 6.7 ft.

W from E line bldg. 2.8 ft.

June 20, 1977: Leak over tap. Repair from main to 2 ft. front of main. 2 ft.-3/4" copper; 5/8" x 3/4" lead to copper adapt. XS; 3/4" x 3/4" Figure 413; tap reamed;

Oct. 26, 1979: Renewed 6" outside curb stop to property line.

8 ft. - $3\frac{3}{4}$ " copper

1-3/4" curb stop

2-5/8" x 3/4" lead-cop, adapt. XXS

1-Caldwell stop box

2-5/8" x 3/4"

INACTIVE SER

[illegible]

CHARGE OUTS

[illegible]