

APPLICATION No.: 6107

TAP CLEARED 8952-0956

LOCATION: 157 Grinnell St.

OWNER: John M. Santos

DATE BEF. AFT. REMARKS

12/27/89 TAP REAMED

MEASURES: 5/8"

H lead

Oct. 8, 1874

Apr. 12, 1889

W from

County St.

197.4 ft.

S from N line

Grinnell St.

7.0 ft.

W from E line

house

10.4 ft.

5/12/78: Renewed 6" outside curbstop to the line.

8 ft. - 3/4" copper; 3/4" curb stop; Caldwell stop box;

2-5/8" x 3/4" lead to cop. adapt. XXS

12/27/89: Renewed from main to curb stop

Stock; 16 ft. 3/4" copper tubign 1-3/4x3/4 cop to cop

cplg. comp. 1- 3/4x5/8 Fig. 413

5/30/2019: Lead service line replacement program phase 1

Contractor P. Gioioso & Sons. TYPE CU, Diameter 1"

Water Pressure 100

Distance from main to curb stop N/A

Distance curb stop to meter 20'

Distance from curb face to curb stop 1'

Depth of service 4'

Total length of new pipe installed 20'

Curb stop replaced: NO Size N/A

Corporation replaced: NO Size N/A

Ball Valve furnished: YES Size 1"

METER HISTORY

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS
2-4-67		5/8	Rock Mg.	19768698					

CHARGE OUTS

