

6112

APPLICATION No.:

TAP CLEARED

LOCATION: 32 1/2 & R Acushnet Ave

DATE

BEF.

AFT.

REMARKS

OWNER:

31-313

MEASURES:

April 15, 1889

S from Blackmer St 163,9'

W from E Line Acushnet Avenue 7.3'

S from N line house 11.3'

1" COPPER SERVICE

5/17/2019: Lead service line replacement program

phase 1: TYPE CU: Diameter 1: Water Pressure 100

Contractor: P. Gioioso & Sons

Distance from main to curb stop 20'

Distance curb stop to meter 64.5'

Distance from curb face to curb stop 2.3'

Depth of service 4.5'

Total length of new pipe installed 64.5'

Curb Stop replaced NO: Size 3/4"

Corporation replaced NO: Size 3/4"

Ball Valve furnished YES: Size 1"

Comments: 1- 3/4" union installed 1ft outside

curb stop

12-29-1981 Tap rea

[illegible]

CHARGE OUTS

