

APPLICATION No.: 6167TAP CLEARED 8826-2680LOCATION: 170 Division St.OWNER: Paul De MelloSchlumberger

MEASURES:

1/2" A

H lead

May 31, 1889

E from

Crapo St.

399.3 ft.

N from S line

Division St.

6.4 ft.

E from W line house

11.4 ft.

9/24/80: Renewed from main to a point 2.0 ft. from main.

2.0 ft.-3/4" copper

1-5/8" x 3/4" Fig. 413 Tap Reamed

1-5/8" x 3/4" lead-cop. adapt. XS
- - - -

7/1/88: Renewed from 1/2' outside curb stop to a point 4 f.t

Stock: 4.5 ft. 3/4" copper tubing 1-3/4" curb stop

1 - Caldwell stop box 2-3/4x5/8 lead to cop adapt. xs.
=====✓ NOTE: GAS SERVICE OVER WATER SERVICE DRAIN MANHOLE FLOODS
WATER TRENCH

✓ 4/20/93: Renewed from main to ins.cellar (12ft ins.propline)

Stock: 30ft 3/4" copper tubing 1-3/4" curb stop

1-Caldwell stop box 1-3/4" corp tap 1-6x3/4 service saddle
=====

DATE

BEF.

AFT.

REMARKS

SEP 24 1980

4-5-
93Reamed9314 2534

[illegible]