APPLICATION No.: 6179	TAP CLEARED			
LOCATION: 183 Washington St	DATE	BEF.	AFT.	REMARKS
OWNER:				,
MEASURES: E X Dartmouth St S X N Line Washington St E X W Line House 1" Copper Service 10/01/2018 Lead Service Line Replacement Program Phase 1, Contractor P Gioioso & Son Type CU, Diameter 1in, Water pressure 80 Distance from main to curb stop (ft) 20.2 Distance curb stop to meter (ft) 17.6 Distance from curb face to curb stop (ft) 1.6 Depth of service (ft) 4.3 Total length of new pipe installed (ft) 37.8 Curb stop replaced: Yes size 1" Corporation replaced: Yes size 1" Ball valve replaced: Yes size 1"				

