

APPLICATION No.: 6198

TAP CLEARED

LOCATION: 72 Mt. Pleasant

OWNER: Michael Bocielek

MEASURES: 3/4"

N from

Weld

44.3 ft.

W from E line

Mt. Pleasant

~~XXXXXX~~ 3.0 ft.

S from N line

House

2.6 ft.

Feb. 3, 1953 Renewed from curb stop to inside cellar.
18 ft. - 3/4" Copper tubing

2/19/80:

- - -

Renewed from curb stop to a point 3.0 ft. outside
curb stop. 3.0 ft. - 3/4" copper; ^{two} 3/4" curb stop; 5/8" x
3/4" lead-cop. adapt. XXS; Same stop box;

AUG 11 1981 - Renewed service from the 8" main to the
property line. 14 ft. - 3/4" copper; 3/4" curb stop; stop
box; 5/8" x 3/4" lead-cop. adapt. XXS; 3/4" x 3/4" Fig.
413; Note: No saddle used on transite pipe.

DATE

BEF.

AFT.

REMARKS

AUG 11 1981

tap reamed

[illegible]

CHARGE OUTS

[illegible]