

6226

LOCATION: 24 Welcome St

OWNER:

31-313

MEASURES: E X French Ave

N X S Welcome St

E X W House

1" Copper Service 4/25/2019

Lead Service Line Replacement Program

Phase 1, Contractor P Gioioso &amp; Son

Type CU, Diameter 1in, Water pressure 100

Distance from main to curb stop (ft) N/A

Distance from curb stop to meter (ft) 21.5

Distance from curb face to curb stop (ft) 1

Depth of service (ft) 4

Total length of new pipe installed (Ft) 21.5

Curb stop replaced: No

Corporation replaced: No

Ball valve replaced: Yes size 1"

TAP CLEARED

DATE \_\_\_\_\_

BEF.

AFT.

REMARKS

7/10/67 Ream

9/17/04	
---------	--

[illegible]

APPLICATION No.: 6226

TAP CLEARED ✓

LOCATION: 24 Welcome

OWNER: Fridertle

MEASURES:  $\frac{1}{2}$ "

E from	French Ave.	150.6 ft.
N from S	Welcome	8.9 ft.
E from W	house	2.5 ft.

-----  
July 10, 1967 Renewed from main to the curb stop.  
8 ft. of  $\frac{3}{4}$ " copper tubing used. Total.  
1  $\frac{5}{8}$ " reused tail piece.  
-----

Dec. 6, 1965 Renewed from 6" outside curb stop to 4 ft. inside curb stop  
 $4\frac{1}{2}$  ft. of  $\frac{3}{4}$ " copper tubing 1  $\frac{3}{4}$ " cop. to cop. stop  
2 lbs. wiping solder  
-----

10/6/04 Renewed from curb stop to property line. Stock: 8 ft.  $\frac{3}{4}$ "  
copper tubing;  $\frac{5}{8}$ " x  $\frac{3}{4}$ " lead-cop adapt. XS  
-----

DATE

BEF.

AFT.

REMARKS

7-10-67

Reamed

9-17-04

2004-380-3882



[illegible]

## CHARGE OUTS

[illegible]