

APPLICATION No.: 6253

TAP CLEARED

✓

LOCATION: 90 Shawmut Ave.

OWNER: Frank O Anderson

MEASURES: $3/4"$

S from Locust 105.4 ft.

W from E line	Shawmut Ave.	6.3 ft.
---------------	--------------	---------

S from N line	Body house	12.2 ft.
---------------	------------	----------

Oct. 31, 1977: Leak at curb stop. Renewed 6" outside curbstop to prop. line. 8 ft.-3/4" copper; 3/4" curb stop; 2-5/8" x 3/4" lead to copper adapt XXS; Caldwell stop box (no one home to ask to go into cellar with copper)

MAY 17 1982 -- Tilcon renewed from the main to the curb stop. 20.0 ft.-3/4" copper; 1" x 3/4" Fig. 413;

100 200 300 400 500

[illegible]

CHARGE OUTS

[illegible]