

APPLICATION No.: 6261

TAP CLEARED ✓

LOCATION: 117 Willis

OWNER: Annie M. Trey

MEASURES: 3/4"

E from	Cedar	61.0 ft.
S from N	Willis	5.3ft.
E from W	house	12.1 ft.

March 15, 1973 Renewed from the main to inside  
cellar.

37 ft. - 3/4" Copper tubing ( 11 ft. inside)  
3/4" Hays curb stop Caldwell Stop Box  
3/4" x 1" Hays Fig. 413  
- - -

Dec 12, 1996: Trench caved in pulling tap from main  
Shoring box removed from trench causing collapse  
Renewed from main to a point 8ft 9in north from main  
Stock: 8ft 9in 3/4" copper tubing 1-3/4x3/4 cop-cop cplg.comp  
1- 3/4" corporation tap 1-6"x3/4" service saddle (bronze)  
M Rose III P Reynolds  
=====

DATE

BEF.

AFT.

REMARKS

3-15-73

Reamed

[illegible]