

APPLICATION No.: 6264---5/8"

TAP CLEARED

LOCATION: 1416 Acushnet Av.

OWNER: Lillian Barnes

MEASURES: 5/8" H.lead Sept. 23, 1889
 S from Deane 139.0 ft.
 W from E line Acushnet Av. 8.3 ft.
 N from S line house 13.6 ft.

1/17/78: Renewed 6" outside curbstop to the line. 7½ ft. 3/4"
 copper; 2-5/8" x 3/4" lead to cop. adapt. XXS; 3/4" curb
 stop; Caldwell stop box; -----

New Measures for 3/4" copper service - 3/7/08
 W from N line Bullard St 69.0
 W from E line Acushnet Ave 7.0
 N from S line House 14.0
 S from N line House 11.0
 W from W line House 11.0
 Main to property line 36.0
 Pipe inside property 8.0

3/2/08 - Do Not Turn Service ON - Owner needs to replace lead
 service and install a shut-off before the meter, currently no
 meter at this location. Paul Monteiro says broken pipes inside
 per Wayne Richmond. -----

3/7/08 - R.J. Canessa renewed service from main existing tap into
 cellar. Stock: 44 ft - 3/4" copper tubing.
 Owner charged \$70 for Inspection. Inspected by Percy Reynolds

DATE

BEF.

AFT.

REMARKS

[illegible]

CHARGE OUTS

[illegible]