

6284

35 Circuit St.

31-313

MEASURES:

Date 10/16/2019 Contractor: City of New Bedford
Size ¾" Type of pipe : Copper
CiCrbX Cast iron Curb Stop Boxes- Units 0 UOM Each
Cop-.75 Box of ¾" Copper Tubing – Units 33 UOM Feet
BValve-3/ ¾" Ball Valve 4 – Units 1 UOM Each
FSxFT ¾" Female Sewat x ½" 90-.75x5. Female Thread 90

Curb stop to meter replacement

TAP CLEARED

DATE _____

BEF.

AFT.

REMARKS

[illegible]

APPLICATION No.: 6284

TAP CLEARED

LOCATION: 35 Circuit St.

DATE

BEF.

AFT.

REMARKS

8/29/80

Reamed

OWNER: Edward Ferreira

MEASURES: 5/8" H lead Oct. 1, 1889

7/27/94: tap reamed

W from W line Bolton St. 364.2 ft.

S from N line Circuit St. 10.6ft = 6.6 ft.

E from W line house 16.6 ft.

Service enters house W from E line 8.8 ft.

Tap:

W from E line House 19.2 ft.

S from Sline House 54.5 ft.

Dec. 28. 1972 Renewed from 6" outside curb stop to a point 4 ft. from the curb stop

2 wipe joints

Stock: 4 1/2' - 3/4" Copper tubing

1 - 3/4" Hays curb stop

82/9/80: Renewed from main to a point 2.5 ft. from main.

2.5 ft. - 3/4" copper; 5/8" x 3/4" Fig. 413; 5/8" x 3/4"

lead-cop. adapt. XXS

7/27/94: Biszko Cont. renewed from main to prop line during cement lining Cont. to supply all stock & maintain trench:

32ft 3/4" copper tubing 1-3/4" curb stop 1-Caldwell stop box
1-3/4x5/8 lead-cop adapt. xxs re-used same Fig 413

Insp. F Bento S X N LINE CIRCUIT ST 10.6ft

[illegible]

CHARGE OUTS

Date:

7-19-96

Out

A.M. In
P.M.A.M.
P.M.

Driver:

Ken M. Dunch

Where called:

35 Circuit St. 307 Bolton

Meter Removed: Type:

94 Hawthorn St. 296 Dartmouth

No.:

Type Sidewalk:

St.

Horses—Lights—Signs—

Leak: Main to curb stop ☐Shut off at curb stop ☐curb stop to property ☐Shut off at meter stop ☐Leak inside building ☐Turned on at curb stop ☐

Remarks:

35 Circuit Check leak in
cellar before meter, no damage
calling back Monday, 10 to 8 punch.
307 Bolton Hole in side walk and
street need fill and cold patch.
296 Dartmouth OK could use a little
cold patch
94 Hawthorn St. need cold patch.

