

LOCATION: 397 Union St. APPLICATION No.: 6324

OWNER: _____

31-313

MEASURES:

TAP CLEARED

DATE	BEF.	AFT.	REMARKS
------	------	------	---------

Measures: $\frac{3}{4}$ " COPPER

N X N Line	UNION ST	33'
E X W Line	ASH	7.1'
S X N Line	HOUSE	7.2'
N X S Line	HOUSE	28'
E X E Line	HOUSE	7.1'

MAIN TO PROPERTY LINE 14'

PIPE INSIDE PROPERTY LINE 4'

MEASUREMENTS TAKEN 9/5/2023

CONTRACTOR : JLC CONSTRUCTION

Curbstop to meter repair

[illegible]

CHARGE OUTS

APPLICATION No.: 6324

TAP CLEARED 8448-0123

LOCATION: 397 Union Cor. Ash.

DATE BEF. AFT. REMARKS

OWNER: Jolin J Reaney

MEASURES: 5/8"

11/27/84 tap reamed

8539-1014

N from Union
E from W line Ash
S from N line house

33.0 ft.

7.1 ft.

7.2 ft.

4/14/97: tap reamed

4/14/97 9716-00256

NOv.27,1984: Renewed from main to a point 1.0ft.
Stock:1.0ft. 3/4" copper tubing 1 3/4" x 5/8
lead to cop adapt comp. XS 1 5/8" Fig.413

9/24/85: Renewed from 1/2' outside curb stop to a point 3.5 ft.
Stock: 4.0 ft. 3/4" copper tubing 1 - 3/4" curb stop
1 - Caldwell stop box 2 - 3/4x5/8 lead to cop adapt. comp.xxs

Lead serv.replacement:

April 14,1997: Renewed from main to prop line
Stock: 13'ft 3/4" copper tubing 1-3/4" curb stop
same Caldwell stop box 1-3/4x5/8 lead-cop adapt.xs
1- 3/4 x 5/8 Fig 413

[illegible]

CHARGE OUTS