

~~49~~ APPLICATION No.:

TAP CLEARED 8814-4106

LOCATION: West Elm, Cor. Florence - 49

DATE \_\_\_\_\_

BEF.

AFT.

REMARKS

OWNER: Joseph E. Mac Larlame

1/5/54

reamed

MEASURES:  $3/4"$

W from	Florence	48.8
S from N line	Elm	7.2
E from W line	House	2.7

Jan. 5, 1954 Renewed from a point 2 ft. outside curb stop to  
property line 9 ft. of 3/4" copper tubing  
3/4" copper stop, fig. 415 3/4" cop. to I. F. cplg., fig 413  
3 wiped joints

4/7/88 Renewed from 1' outside curb stop to a point 5 ft  
6ft-3/4" copper tubing, 1-3/4" curb stop, 1-Caldwell stop box  
2-5/8x3/4 lead to cop adapt xs

*S. longica* 5/31/88 25 ft pencil leaf  
inside of cellar -----

9/19/08 - West End Water Main Rehab Contract #4 - Perrina Const.  
Renewed service from main to a point 3 ft inside curb stop  
19.5 ft - 1" copper tubing; 1 - 1" Corp Tap; 1 - 1" curb stop;  
1 - 1" x 3/4" reducer. Inspected by Tim Ives, CDM

[illegible]

## CHARGE OUTS

[illegible]



APPLICATION No.: 6358

TAP CLEARED ✓

LOCATION: West Elm, Cor. 49 Florence

OWNER:

MEASURES:

 $\frac{3}{4}$ "

W from	Florence	48.8
S from N line	Elm	7.2
E from W line	House	2.7

DATE

BEF.

AFT.

REMARKS

[illegible]

## CHARGE OUTS

[illegible]