

APPLICATION No.: 6389

## TAP CLEARED

LOCATION: 84 Rockland St

DATE

BEF.

AFT.

REMARKS

OWNER:

1/28/91 Ream

31-313

MEASURES:

April 5, 1890

W X Hall St

57.8 ft

N X S Line Rockland St

6.6 ft

W X E Line House

6.4 ft

1" Copper Service

10/30/2018 Lead Service Replacement Program

Phase 1, Contractor P Gioioso &amp; Son

Type CU, Diameter 1in, Water pressure 90

Distance from main to curb stop (ft) 8

Distance from curb stop to meter (ft) 19

Distance from curb face to curb stop (ft) 1.5

Depth of service (ft) 5

Total length of new pipe installed (ft) 27

Curb stop replaced: Yes size 1"

Corporation replaced: Yes size 1"

Ball valve replaced: Yes size 1"

[illegible]