

APPLICATION No.: 6392

TAP CLEARED

LOCATION: 367 Sawyer

OWNER: Mikolaj Jaremko

MEASURES:

 $\frac{1}{2}$ "

E from	Purchase	250.8 ft.
S from N line	Sawyer	9.2 ft.
E from W line	House	10.0 ft.
E from E line	Brook	24.0 ft.

-----  
March 12, 1957 Renewed from a point 3 ft. from tap to tap.  
3 ft. of  $\frac{3}{4}$ " copper tubing 1  $\frac{3}{4}$ " cop. to I.F. Cplg.  
1 lb. wiping solder  
-----

Street reconstruction June 12, 1997  
Renewed from main to prop line  
Stock: 32ft  $\frac{3}{4}$ " copper tubing 1- $\frac{3}{4}$ " curb stop  
1-caldwell stop box 1- $\frac{3}{4}$ x $\frac{5}{8}$  lead-cop adapt.xs  
1- $\frac{3}{4}$ x $\frac{5}{8}$  Fig 413  
=====

1" Copper Service  
08/22/2018 Lead Service Replacement Program  
Phase 1, Contractor P Gioioso & Son  
Type CU, Diameter 1in, Water pressure 70  
Distance from main to curb stop (ft) N/A  
Distance curb stop to meter (ft) 17  
Distance from curb face to curb stop (ft) 1.5  
Depth of service (ft) 3.3  
Total length of new pipe installed (ft) 17  
Curb stop replaced: NO Corporation Replaced:NO  
Ball valve replaced: Yes Size 1"

DATE

BEF.

AFT.

REMARKS

3-12-57

Reamed

6/12/97: tap reamed

[illegible]

# CHARGE OUTS

