

APPLICATION No.: 6394

TAP CLEARED 8908-0056

LOCATION: 2 Stanton Ct.

OWNER: Ernest Aguiar

MEASURES: 1"

W from Hall 43.2 ft.

N from S line Ct. 2.7 ft.

W from E line House 8.0 ft.

1/12/79: Renewed from main to inside cellar wall. 20 ft.-
3/4" copper (6 ft. inside); 3/4" curb stop; 5/8" x 3/4"
Fig. 413; Caldwell stop box;

9/19/94: Bisxko Cont. renewed from new 8" main to a point
1ft in front of main Cont. supplied all stock & will maintain
trench 1ft 3/4" copper tubing 1-3/4x3/4 cop-cop cplg.comp
1-3/4" corporation tap Insp. F Bento

DATE

BEF.

AFT.

REMARKS

8-7-
92

9232 5436

Main sewer was broken while
digging. M. Torres was very
upset. E. Tavares from D.P.W.
repaired it.

[illegible]

CHARGE OUTS

[illegible]