

APPLICATION No.: 6425

TAP CLEARED

LOCATION: 233 North St

OWNER: Patrick Flattery

MEASURES: 5/8"

E from	Newton	73.1
S from N Line	North	3.9
E from W line	House	12.2
S from S line	House	4.6

9/27/91: Renewed from curb stop to ins.cellar
9ft. ins.prop line Stock: 13ft. 3/4" copper tubing
same curb stop same Caldwell stop box.

DATE

BEF.

AFT.

REMARKS

9/27/91:

91394917

METER HISTORY

[illegible]

CHARGE OUTS

This image shows a blank, aged, cream-colored page, likely an endpaper or flyleaf of a book. The paper has a slightly textured appearance with some faint smudges and discoloration, characteristic of old paper. The left edge of the page shows the binding, with visible stitching or staples. There is no text or other markings on the page.

APPLICATION No.: 6425

TAP CLEARED

LOCATION: 233 North St.

OWNER: Patrick Flattery

MEASURES: 5/8"

\$ 375⁰⁰

E from	Newton	73.1
S from N line	North	3.9
E from W line	House	12.2
S from S line	House	4.6

May 27, 1975 Renewed from the main to a point 4½ ft. from the main.

4½ ft. - 3/4" Copper tubing 3/4" x 3/4" Fig. 413

5/8" lead to copper adaptor XS

Dec. 8, 1959 Renewed from curb stop to 3 ft. inside curb stop

3 ft. - 3/4" Copper tubing 2# wiping solder

Jan. 7, 1976 Renewed from the new 30" main in North St. to the property line.

26 ft. - 3/4" Copper tubing 3/4" Jones corporation

3/4" Jones curb stop Buffalo stop box

5/8" x 3/4" Ford lead to cop. adaptor XS (at prop line)

6/18/91 Check for leaks signs of water coming in under foundation cannot hear no leaks H. Hunt

DATE	BEF.	AFT.	REMARKS
------	------	------	---------

5/27/75

RENEWED

9/27

91394917

[illegible]

CHARGE OUTS