

APPLICATION No.: 644

TAP CLEARED

LOCATION: 257 Acushnet Ave.

OWNER: Lorenca R. Gomes

MEASURES: 5/8" H lead May 29, 1871
 S from Walnut St. 76.8 ft.
 E from W line Avenue 7.2 ft.
 N from N line body of house 0.7 ft.

June 24, 1968 Renewed from 1½' inside property line to cellar
 5' - 3/4" copper tubing; 1 wipe joint
 All work done by owner's plumber.

Jan. 30, 1979: Renewed from 6" outside curbstop to a point
 4.5' inside. 5 ft. - 3/4" copper; 3/4" curb stop; 2-5/8" x
 3/4" lead to cop. adapt. XXS; Caldwell stop box;

Mar. 27, 1980: Franklin Const. renewed service from the main
 main to a point 2 ft. short of prop. line. (Sewer in
 the way)
 12 ft. - 3/4" copper
 1-3/4" curb stop
 1-3/4" x 5/8" Fig. 413
 1-3/4" x 5/8" lead-cop. adapt. XX
 (2 ft. from line)

call dirty water at different times 8/28/83

METER HISTORY

CHARGE OUTS

[illegible]