

APPLICATION No.: 6452

TAP CLEARED

LOCATION: 168 Grinnell St

OWNER: _____

31-313

MEASURES: April 21, 1890

S X Grinnell St 33.3 ft

W X E Line Crapo St 7.3 ft

N X S Line House 10.6 ft

1" Copper Service

09/10/2018 Lead service line replacement program

Phase 1, Contractor P Gioioso & Son

Type CU, Diameter 1in, Water pressure 80

Distance from main to curb stop (ft) 20.7

Distance from curb stop to meter (ft) 8

Distance from curb face to curb stop (ft) 1.5

Depth of service (ft) 4.3

Total length of new pipe installed (ft) 20.7

Curb stop replaced: yes size 1"

Corporation replaced: yes size 1"

Ball valve furnished: no size 3/4"

Remarks: Service located off Crapo St

1-3/4 union installed 1.0 lf outside curb stop

DATE

BEF.

AFT.

REMARKS

METER HISTORY

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS

CHARGE OUTS

