

✓ APPLICATION No.: 6464

LOCATION: 85 Winsor St

OWNER:

31-313

MEASURES:	E X Crapo St	100.9 ft
	S X N Winsor St	9.1 ft
	E X W House	3.5 ft

1" Copper Service 7/15/2019

Lead Service Line Replacement Program

Phase 1, Contractor P. Gioioso & Son

Type CU, Diameter 1in, Water pressure 100

Distance from main to curb stop (Ft) 24.5

Distance curb stop to meter (ft) 13

Distance from curb face to curb stop (ft) 2

Depth of service (ft) 4.3

Total length of new pipe installed (ft) 24.5

Curb stop replaced: Yes size 1"

Corporation replaced: Yes size 1"

Ball valve replaced: No size 3/4"

Remarks: new tap at main, existing corp abandoned
1-3/4" union installed 1 ft outside curb stop

TAP CLEARED

DATE _____

BEF.

AFT.

REMARKS

6/22/67 Ream

[illegible]

CHARGE OUTS

