

31

APPLICATION No.: 6493

TAP CLEARED I-12 44-V

LOCATION: 96 Acushnet Ave.

OWNER: Joseph R. Silva

MEASURES: 1/2"

H lead

June 4, 1890

N from

Rockland St.

23.0 ft.

W from E line

Avenue

7.2 ft.

N from S line

house

12.3 ft.

9/8/81: Renewed from main to 6 ft. outside main.

6.0 ft. - 3/4" copper; 5/8" x 3/4" Fig. 413; 5/8" x 3/4" lead-cop. adapt. XS

6/10/86: Renewed from 1/2' outside curb stop to ins. cellar.

(12.0 ft. ins. prop line) Stock: 20.0ft. 3/4" copper tubing

1 - 3/4" curb stop 1 - Caldwell stop box 1 - 3/4 x 5/8 lead to cop adapt. comp. xs

1-2-2019: Lead service line replacement program phase 1
Type: CU, Diameter 1"

Distance from MAIN to curb stop 20.2'

Distance from curb face to curb stop 2.2'

Depth of service 3.8'

Total length of new pipe installed 21'

CurB stop replaced YES: Size 1"

Corporation replaced YES Size 1"

Ball Valve furnished NO Size -

New 1" corporation New 1" curBstop

Distance from curb stop to Meter (ft): N/A

DATE

BEF.

AFT.

REMARKS

9/8/81-

Tap reamed

8624-1063

[illegible]

This image shows a blank, aged, cream-colored page, likely an endpaper or flyleaf of a book. The paper has a slightly textured appearance with some faint smudges and discoloration, characteristic of old paper. There is no text or other markings on the page.

