APPLICATION No.: 6518

LOCATION: 574 Kempton

OWNER: Albert Beauregard

MEASURES: 18ft 3/4"

E from	Liberty	55.1 ft.
N from S line	Kempton	7.1 ft.
E from W line	House	12.1 ft.

Jan. 3, 1976 Repaired leak - tap blew out.
1 ft. - 3/4" Copper tubing 1- 3/4" Corporation
8" x 3/4" Adams Saddle 5/8" x 3/4" lead conn.

- - -

8/26/91: Ch 90 proj. Capaldi Brow renewed from main to prop line
Stock: 18ft 3/4" copper tubing 1-3/4" curb stop 1-Caldwell stop box 1-3/4x5/8 lead-cop adapt.xxs 1-3/4x5/8 Fig.413
Insp R Smalley==========

TAP CLEARED

DATE	BEF.	AFT.	REMARKS
8/26/91:	TAP	REAMED	

METER HISTORY

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS
9-4-62		5/8	Cadmet	1764936					

CHARGE OUTS