

APPLICATION No.: 6554

TAP CLEARED

LOCATION: 163 County St.OWNER: Saint Hyacinth, R.C. Parish

DATE

BEF.

AFT.

REMARKS

5/17/75

Reamed

MEASURES: $\frac{1}{2}$ " H lead July 24, 1890

N from Rivet St. 55.0 ft.

E from W line County St. 4.5 8.5 ft.

S from S line house 35.0 ft.

May 17, 1975 Renewed from the main to the prop. line.

✓ 15 ft. - $\frac{3}{4}$ " Copper tubing $\frac{3}{4}$ " Curb Stop5/8" lead to copper adapt. XS 5/8" x $\frac{3}{4}$ " Fig. 413

Caldwell Stop Box

✓ Broke electric duct located 2 ft. E x W line curbing.
Cable was not marked out.

INACTIVE SER

[illegible]

CHARGE OUTS

[illegible]