


APPLICATION No.: **6562**TAP CLEARED LOCATION: **147 Pleasant**OWNER: **M. DeSilva**

MEASURES:

5/8"**S from Wing 90.2****E from W line Pleasant 7.6****N from S line house 7.1**

Oct. 28, 1976 Renewed from 6" outside curb stop to the property line.

8 ft. - 3/4" Copper tubing 3/4" Curb Stop
Caldwell Stop Box 2- 5/8" x 3/4" lead to
 cop. adapt. XXS

- - -
Owner lives in Dartmouth & could not be reached to renew in cellar.

October 15, 2002: Renewed from main to inside cellar (5 ft.ins.prop. line); 18 ft. - 3/4" copper tubing; 1 - 3/4" curb stop; 1-caldwell stop box; tap reamed

DATE

BEF.

AFT.

REMARKS

*10/24/02**8:30 am**2002 430 7333*

[illegible]

CHARGE OUTS

[illegible]