

APPLICATION No.: 6649

TAP CLEARED

LOCATION: 52 Hall St

OWNER:

31-313

MEASURES: November 1, 1890

N X Thompson St 101.5 ft

W X E Line Hall St 6.4 ft

N X S Line House 7.1 ft

1" Copper Service

12/04/2018 Lead Service Line Replacement Program

Phase 1, Contractor P Gioioso & Son

Type CU, Diameter 1in, Water pressure 90

Distance from main to curb stop (ft) 19.4

Distance from curb stop to meter (ft) 20.1

Distance from curb face to curb stop (ft) 1.8

Depth of service (ft) 4.4

Total length of new pipe installed (ft) 39.5

Curb stop replaced: yes, size 1"

Corporation replaced: yes, size 1"

Ball valve replacedL yes, size 1"

Remarks: service saddle with 1" corp installed on

6" water main

DATE

BEF.

AFT.

REMARKS

[illegible]