

APPLICATION No.: 6664

TAP CLEARED



LOCATION: 144 Richmond

OWNER: Mulbeey

MEASURES:

3/4"

N from Austin

138.7

W from line Richmond

6.5

S from N line house

10.2

August 21, 1980 Machine caught on service tap of this house while cement lining. Service retapped on a new piece of 6" Ductile pipe installed with cplgs.

1 - 3/4" Corporation Tap 3 ft. - 3/4" Copper tubing

1 - 3/4" x 3/4" lead to copper adaptor

- - -

APR 21 1982 --Tilcon renewed service from the main to the property line. 33.0 ft. -3/4" copper; 3/4" curb stop; stop box, 1" x 3/4" Fig. 413; 5/8" x 3/4" lead-cop. adapt. XXS

7/11/06 Renewed from property line to inside cellar.  
Stock: 15 ft. 3/4" copper tubing; 3/4" x 3/4" cop-cop  
cplg. comp  
-----

DATE

BEF.

AFT.

REMARKS

7/11/06 S AM 2006 280 2906

[illegible]

## CHARGE OUTS

[illegible]