

APPLICATION No.: 6743

TAP CLEARED

LOCATION: 219 North Cor. Park

OWNER: Wm H.S. Preede

MEASURES: $5/8''$

E from	Park	17.4 ft.	18.0
S from N line	North	6.9 ft.	5.0
W from E line	House	10.9 ft.	
E x W line	House		13.6
S x S line	House		9.0

February 9, 1959 Renewed form $\frac{1}{2}$ ft. outside curb stop
to 2 ft. inside curb stop
 $2\frac{1}{2}$ ft. of $\frac{3}{4}$ " copper tubing type K, soft
 $1\frac{3}{4}$ " cop. to cop. stop, fig. 415 2 lbs. wiping solder

June 8, 1950 Leak at tap. #1 Solder. no pipe used.

Dec. 26, 1975 Renewed from the new 30" main in North St. to the property line.

26 ft. - 3/4" Copper tubing 3/4" Hasy corporation
3/4" Jones curb stop C.F. Buffalo stop box
5/8" x 3/4" Ford lead to cop. adapt. XS ((prop. line)

11/3/2009- This service has a leak inside the private property + needs to be repaired when water service is turned on.

2/2/10- See NEW MEASURES
Attached

[illegible]

CHARGE OUTS

[illegible]

6743

TAP CLEARED

OWNER:

31-313

MEASURES: 3/4" Copper

E from E line Park St	18.0
S from N line North St	5.0
W from E line House	11.0
E from W line House	13.6
S from S line House	9.0
Main to Property Line	25.0
Pipe inside Property	7.0

2/2/10 - Dennis Trucking renewed service from curb stop to meter (New measures above) Owner charged \$115 (\$45 turn-on fee & \$70 Inspection fee).
Inspected by Percy Reynolds

[illegible]