

APPLICATION No.: 6758

TAP CLEARED 8931-5207

LOCATION: 22 Cottage St.

OWNER: William De Costa Et Ux #9978946

MEASURES: 5/8" A H lead Apr. 23, 1891

N from Bay St. 19.5 ft.

WA from E line Cottage St. 6.9 ft.

S from N line house 4.3 ft.

8/4/89: Renewed from main to a point 2 ft. Stock: 2ft. 3/4"
copper tubing 1-3/4x5/8 lead to cop adapt. xxs
1 - 3/4x5/8 Fig. 413 =====

8/7/91: Renewed from main to ins. cellar (7ft. ins. prop
line) Stock: 34ft. 3/4" copper tubing 1-3/4" curb stop
1-Caldwell stop box re-used Fig. 413
=====

July 12, 1995:

W Walsh cement lining:

Removed blocked 5/8" tap & installed 1-6 x 3/4 service saddle
and new 3/4" corporation tap. Used existing copper
6" pipe too weak & brittle could not pick up treads
Street cut 6x7 to be maintained by W Walsh
by Jos. Rodrigues

DATE BEF. AFT. 8/1 REMARKS ✓

8/4/89: TAP REAMED 9131-3616

8/7/91: TAP REAMED

[illegible]

CHARGE OUTS

[illegible]