APPLICATION No.:6775	TAP CLEARED			
LOCATION: 24 W Rodney French Blvd	DATE	BEF.	AFT.	REMARKS
OWNER:	9/30/71	Rear	n	
MEASURES: S X N Welcome St W X E Line W Rodney French N X S Line Body of House  58.7 ft 4.4 ft 11.0 ft	7/30/8	Rear	n	
1" Copper Service 4/22/2019 Lead Service Line Replacement Program				
Phase 1, Contractor P Gioioso & Son				
Type CU, Diameter 1in, Water pressure 100 Distance from main to curb stop (ft) 46 Distance curb stop to meter (ft) 18.8 Distance from curb face to curb stop (ft) 2.3 Depth of service (ft) 4 Total length of new pipe installed (Ft) 18.8 Curb stop replaced: No size 3/4"				
Corporation replaced: No size 3/4"				
Ball valve replaced: Yes size 1" Remarks: 1-3/4 union installed 1Ft outside curb stop				
				,

